



4 B EVES DRIVE SUITE 200 MARLTON, NJ 08053
TEL: (856) 985-5600 FAX: (856) 985-6464

April 27, 2009

Mr. Jim Bleckley, Administrator
Rabun County
25 Courthouse Square Box 8
Clayton, GA 30525

RE: Rabun County FD, Rabun County, GA
Public Protection Classification: 5/9
Effective Date: August 1, 2009

Dear Mr. Jim Bleckley:

We wish to thank you, Fire Chief Mike Hopkins and Mr. Moody Barrick for your cooperation during our recent Public Protection Classification (PPC) survey. ISO has completed its analysis of the structural fire suppression delivery system provided in your community. The resulting classification is indicated above.

Enclosed is a summary of the ISO analysis of your fire suppression services. If you would like to know more about your community's PPC classification, or if you would like to learn about the potential effect of proposed changes to your fire suppression delivery system, please call us at the phone number listed below.

ISO is the leading supplier of data and analytics for the property/casualty insurance industry. Most insurers use PPC classifications for underwriting and calculating premiums for residential, commercial and industrial properties.

The PPC program is not intended to analyze all aspects of a comprehensive structural fire suppression delivery system program. It is not for purposes of determining compliance with any state or local law, nor is it for making loss prevention or life safety recommendations.

If you have any questions about your classification, please let us know.

Sincerely,

A handwritten signature in black ink that reads "Richard A. Vance". The signature is fluid and cursive.

Richard A. Vance

(800) 444-4554 Option 2

nf

Encl.

cc: Chief Mike Hopkins, Rabun County Fire Department
Mr. Moody Barrick, Director of Public Works, City of Clayton Public Works

Assistance

The PPC program offers help to communities, fire departments and other public officials as they plan for, budget, and justify improvements. ISO is also available to assist in the understanding of the details of your evaluation.

ISO Public Protection representatives can be reached by telephone at (800) 444-4554. The technical specialists at this telephone number have access to the details of your evaluation and can effectively speak with you about your PPC questions. What's more, we can be reached via the internet at www.isomitigation.com/talk/.

We also have a website that is dedicated to our Community Mitigation Classification programs at www.isomitigation.com. Here, fire chiefs, building code officials, community leaders and other interested citizens can access a wealth of data describing the criteria used in evaluating how cities and towns are protecting residents from fire and other natural hazards. This website will allow you to learn more about ISO's Public Protection Classification program. The website provides important background information and insights about the PPC grading processes. Visitors to the site can download information, see statistical results and also contact ISO for assistance.

In addition, on-line access to the Fire Suppression Rating Schedule and its commentaries is available to registered customers for a fee. However, fire chiefs and community chief administrative officials are given access privileges to this information without charge.

To become a registered fire chief or community chief administrative official, send your request on fire department or chief administrative official's letterhead to:

ISO
Customer Service
545 Washington Boulevard
Jersey City, NJ 07310-1686

Be sure to include your name and title, address, daytime phone number and e-mail address. ISO will send you an e-mail containing your ID and password.

Classification Details

Public Protection Classification

On Jan 12, 2009 ISO concluded its review of the fire suppression features being provided for/by Rabun County FD. The resulting classification is a **Class 5/9**.

If the classification is a single class, the classification applies to all properties in the community. If the classification is a "split" class (e.g., 6/9), the following applies:

- The first class (e.g., "6" in a 6/9) applies to properties within 5-road miles of a recognized fire station and within 1,000 feet of a fire hydrant or alternate water supply.
- Class 8B or class 9 applies to properties beyond 1,000 feet of a fire hydrant but within 5-road miles of a recognized fire station.
- Alternative Water Supply: The first class (e.g., "6" in a 6/10) applies to all properties within 5-road miles of a recognized fire station with no hydrant distance requirement.
- Class 10 applies to properties over 5-road miles of a recognized fire station.